

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1560

Dated: 20-12-2023

It is certified that an inspection team headed by ..Kavits..Kumari..Bochya.....

(Name of Officers with designation) from ..A.En.PHED, Reengus.PHED

inspected the ..Mahala..Residential Public School.....

(Name & Address of the school) on 20-12-2023.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no..2023-24/188..... dated..20-12-2023

of ..Reengus..... (PHED Lab) certified that


the ..Mahala..Residential Public School(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ..03.(Three).Years

Signature with Seal: 

Name सहायक अभियन्ता Kavits Kumari Bochya

Designation जन स्वा. अभि. विभाग P.H.E.D. Engineer

Name & Address of the Office / Department : ..

To ..Mahala..Residential Public School, (A Unit of Shri Shyam Shikshan
..Sansthan). Khakshyamji Road, Reengus, Sikar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

67 | Page


SECRETARY

Mahala Residential Public School
REENGUS, Sikar (Raj.) 332404


PRINCIPAL

Mahala Residential Public School
Reengus, Sikar (Raj.)-332404
Ph. No. : 01575-293131, 7665002931

OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department Laboratory
Reengus, Dist.-Sikar (Rajasthan)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech (them 12023-2024/188)
Reengus, Dist-Sikar (Rajasthan)

Date :- 20/12/2023
District :- Sikar

Source	TW	81510500: 20L2 Drinking Water Standards	
		Max. Desirable Limit	Max. Permissible Limit
Location of Source	Reengus		
Village/Town	Reengus		
Lab Sample No.	u252		
Note: All Results except pfi are in mg/lit			
1. PH	6.89	6.5-8.5	NR
2. Turbid (NTU)	0.88	1	5
3. Temperature (C)			
4. Colour			
5. Odour			
6. Total Alkalinity	230	200	600
7. Total hardness (as CaCO ₂)	180	200	600
8. Calcium Hardness (as CaCO ₃)			
9. Magnesium Hardness (as CaCO ₃)			
10. Chloride (as Cl)	44	250	1000
11. Sulphate (as SO ₄)			
12. Nitrite (as NO ₂)			
13. Nitrate (as NO ₃)	35	45	NR
14. Fluorides (as F')	0.140	1	1.5
15. Total Dissolved Solids	382	500	2000
16. Residual Chlorine			

Remarka

To

Mahala Residential Public School
A Unit of Shri Shyam Shikshan Sansthan)
Khatushyamji Road, Reengus, Dist-Sikar (Rajasthan)
(Name & Address of the institution)

Shubha
Signature With Seal
Name: *Shubha Kumari Bhatia*
Designation: *Asst. Engineer*

Lisal
SECRETARY
Mahala Residential Public School
REENGUS, Sikar (Raj.) 332404

Reena
PRINCIPAL
Mahala Residential Public School
Reengus, Sikar (Raj.)-332404
Ph. No. : 01575-293131, 7665002931

KENT
Health Care

HOUSE OF PURITY

VINAYAK ENTERPRISES**Sale & Service and Spare Parts**

New Katla Market, Khatu Mod, RINGAS (SIKAR)

E:mail : predeepmahala94@gmail.com

Date : 22/02/2024

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that Mahala Residential Public School, Khatushyamji Road, Reengus, Distt. Sikar (Raj.) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.


PRINCIPAL
 Mahala Residential Public School
 Reengus, Sikar (Raj.)-332404
 Ph. No. : 01575-293131, 7665002931


Secretary
 Shri Shyam Shikshan Sansthan
 Reg. No. 890/JPR/2002-03

For VINAYAK ENTERPRISES

 Proprietor